

採水日 項目 検体番号		2025年度 浄水水質検査										最大	最小	平均	参考基準値	定量 下限値
		4月7日	5月13日	6月11日	7月3日	8月19日	9月4日									
		51	591	1329	1785	2771	3334									
1 一般細菌	個/mL	0	0	0	0	0	0							100	-	
2 大腸菌	-	陰性	陰性	陰性	陰性	陰性	陰性							陰性	-	
3 カドミウム及びその化合物	mg/L	---	---	---	---	---	---							0.003	0.0003	
4 水銀及びその化合物	mg/L	---	---	---	---	---	---							0.0005	0.00005	
5 セレン及びその化合物	mg/L	---	---	---	---	---	---							0.01	0.001	
6 鉛及びその化合物	mg/L	---	---	---	---	---	---							0.01	0.001	
7 ヒ素及びその化合物	mg/L	---	---	---	---	---	---							0.01	0.001	
8 六価クロム化合物	mg/L	---	---	---	---	---	---							0.02	0.002	
9 亜硝酸性窒素	mg/L	---	---	---	---	---	---							0.04	0.004	
10 シアン化合物イオン及び塩化シアン	mg/L	---	---	---	---	---	---							0.01	0.001	
11 硝酸態窒素及び亜硝酸態窒素	mg/L	0.2	0.2	0.2	0.2	0.3	0.2							10	0.1	
12 フッ素及びその化合物	mg/L	---	---	---	---	---	---							0.8	0.08	
13 ホウ素及びその化合物	mg/L	---	---	---	---	---	---							1.0	0.02	
14 四塩化炭素	mg/L	---	---	---	---	---	---							0.002	0.0002	
15 1,4-ジオキサン	mg/L	---	---	---	---	---	---							0.05	0.005	
16 シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	---	---	---	---	---	---							0.04	0.001	
17 ジクロロメタン	mg/L	---	---	---	---	---	---							0.02	0.001	
18 テトラクロロエチレン	mg/L	---	---	---	---	---	---							0.01	0.001	
19 トリクロロエチレン	mg/L	---	---	---	---	---	---							0.01	0.001	
20 ベンゼン	mg/L	---	---	---	---	---	---							0.01	0.001	
21 塩素酸	mg/L	---	---	---	---	---	---							0.6	0.06	
22 クロロ酢酸	mg/L	---	---	---	---	---	---							0.02	0.002	
23 クロロホルム	mg/L	---	---	---	---	---	---							0.06	0.001	
24 ジクロロ酢酸	mg/L	---	---	---	---	---	---							0.03	0.003	
25 ジブロモクロロメタン	mg/L	---	---	---	---	---	---							0.1	0.001	
26 臭素酸	mg/L	---	---	---	---	---	---							0.01	0.001	
27 総トリハロメタン	mg/L	---	---	---	---	---	---							0.1	0.001	
28 トリクロロ酢酸	mg/L	---	---	---	---	---	---							0.03	0.003	
29 ブロモジクロロメタン	mg/L	---	---	---	---	---	---							0.03	0.001	
30 ブロモホルム	mg/L	---	---	---	---	---	---							0.09	0.001	
31 ホルムアルデヒド	mg/L	---	---	---	---	---	---							0.08	0.008	
32 亜鉛及びその化合物	mg/L	---	---	---	---	---	---							1.0	0.005	
33 アルミニウム及びその化合物	mg/L	---	---	---	---	---	---							0.2	0.02	
34 鉄及びその化合物	mg/L	0.03未満	0.03未満	0.03未満	0.03	0.03未満	0.03未満							0.3	0.03	
35 銅及びその化合物	mg/L	---	---	---	---	---	---							1.0	0.01	
36 ナトリウム及びその化合物	mg/L	---	---	---	---	---	---							200	0.1	
37 マンガン及びその化合物	mg/L	0.005未満	0.005未満	0.005未満	0.005未満	0.005未満	0.005未満							0.05	0.005	
38 塩化物イオン	mg/L	9.9	10.8	10.5	10.0	10.3	10.3							200	0.2	
39 カルシウム、マグネシウム等(硬度)	mg/L	---	---	---	---	---	---							300	1	
40 蒸発残留物	mg/L	---	---	---	---	---	---							500	1	
41 陰イオン界面活性剤	mg/L	---	---	---	---	---	---							0.2	0.02	
42 ジェオスミン	mg/L	---	---	---	---	---	---							0.00001	0.000001	
43 2-メチルイソボルネオール	mg/L	---	---	---	---	---	---							0.00001	0.000001	
44 非イオン界面活性剤	mg/L	---	---	---	---	---	---							0.02	0.005	
45 フェノール類	mg/L	---	---	---	---	---	---							0.005	0.0005	
46 有機物(全有機炭素(TOC)の量)	mg/L	0.5	1.2	0.5	0.7	0.8	0.6							3	0.3	
47 pH値	-	7.7	7.5	7.8	7.6	7.8	7.8							5.8~8.6	-	
48 味	-	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし							異常なし	-	
49 臭気	-	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし							異常なし	-	
50 色度	度	0.5未満	0.5未満	0.5未満	0.7	0.5未満	0.5							5	0.5	
51 濁度	度	0.1未満	0.1未満	0.1未満	0.2	0.1未満	0.1未満							2	0.1	
52 残留塩素	mg/L	0.3	0.2	0.3	0.5	0.5	0.2							-	-	
53 水温	℃	13.9	18.7	21.2	26.1	29.0	28.5							-	-	